


Annex to Solar Keymark Certificate - Summary of EN ISO 9806:2013 Test Results					Licence Number		011-7S2671 F																	
					Date issued		2017-01-13																	
					Issued by		TÜV Rheinland Energy GmbH																	
Licence holder		Viessmann Werke GmbH & Co. KG			Country		Germany																	
Brand (optional)		Viessmann			Web		http://www.viessmann.com																	
Street, Number		Viessmannstrasse 1			E-mail		---																	
Postcode, City		35107 Allendorf (Eder)			Tel		+49 (0)6452-70-0																	
Collector Type					Flat plate collector, glazed																			
Collector name					Gross area (A_G)		Gross length		Gross width		Gross height		Power output per collector $G_b = 850 \text{ W/m}^2$; $G_d = 150 \text{ W/m}^2$ $\vartheta_m - \vartheta_a$											
					m ²		mm		mm		mm		0 K		10 K		30 K		50 K*		70 K*		90 K*	
Vitosol 200-FM SH2G					2.56		1 070		2 394		90		1 907		1 798		1 528		1 182		828		461	
Power output per m ² gross area					745		702		597		462		323		180									
Performance parameters test method					Steady state - indoor																			
Performance parameters (related to A_G)					$\eta_{0,hem}$		a1		a2															
Units					-		W/(m ² K)		W/(m ² K ²)															
Test results					0.745		3.952		0.033															
Incidence angle modifier test method					Quasi dynamic - outdoor																			
Bi-directional incidence angle modifiers					No																			
Incidence angle modifier					Angle		10°		20°		30°		40°		50°		60°		70°		80°		90°	
Transversal					$K_{GT,coil}$		1.00		0.99		0.98		0.96		0.92		0.86		0.73		0.37		0.00	
Longitudinal					$K_{GL,coil}$		1.00		0.99		0.98		0.96		0.92		0.86		0.73		0.37		0.00	
Heat transfer medium for testing					Water																			
Flow rate for testing (per gross area, A_G)					dm/dt		0.019		kg/(sm ²)															
Maximum temperature difference for thermal performance calculations					$(\vartheta_m - \vartheta_a)_{max}$		90		K															
Standard stagnation temperature ($G = 1000 \text{ W/m}^2$; $\vartheta_a = 30 \text{ °C}$)					ϑ_{stg}		145		°C															
Effective thermal capacity, incl. fluid (per gross area, A_G)					C/m ²		5.86		kJ/(Km ²)															
Maximum operating temperature					$\vartheta_{max,op}$		---		°C															
Maximum operating pressure					$p_{max,op}$		600		kPa															
Testing laboratory					TÜV Rheinland Energy GmbH							http://www.tuv.com/solarthermie												
Test report(s)					21232810.002 21232810.001							Dated		07.07.2016 21.06.2016										
Comments of testing laboratory					As the collectors is operating with a discontinuous performance curve behavior, the performance curve above the switching point of about 50°C (absolute temperature) will be described by the following parameter $\eta_{0,*}$, $a1^*$, $a2^*$ [related to ...]: [A Gross] 0.787 /// 6.202 /// 0.006 The overall behavior (over the full temperature range) is approximately described by the following set of parameters [related to ...]: [A Gross] 0.748 /// 4.427 /// 0.026 ; [A Aperture] 0.822 /// 4.864 /// 0.029							Datasheet version: 5.01, 2016-03-01  TÜVRheinland® Genau. Richtig. TÜV Rheinland Energy GmbH Am Grauen Stein 51105 Köln												
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de																								

Annex to Solar Keymark Certificate Supplementary Information	Licence Number	011-7S2671 F
	Issued	2017-01-13

Annual collector output in kWh/collector at mean fluid temperature ϑ_m, based on EN ISO 9806:2013 test results													
Standard Locations		Athens			Davos			Stockholm			Würzburg		
Collector name	ϑ_m	25°C	50°C	75°C *	25°C	50°C	75°C *	25°C	50°C	75°C *	25°C	50°C	75°C *
Vitosol 200-FM SH2G		2 966	1 915	924	2 159	1 281	576	1 611	917	394	1 756	986	420
Annual output per m ² gross area		1 159	748	361	843	501	225	629	358	154	686	385	164
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m ²			1714 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²		
Mean annual ambient air temperature		18.5°C			3.2°C			7.5°C			9.0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		
The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 5.01 (March 2016). A detailed description of the calculations is available at www.solarkeymark.org/scenocalc													

Additional Information		
Collector heat transfer medium	Water-Glycole	
Hybrid Thermal and Photo Voltaic collector	No	
The collector is deemed to be suitable for roof integration	Yes	
The collector was tested successfully according to EN ISO 9806:2013 under the following conditions:		
Climate class (A, B or C)	A	--
Maximum tested positive load	3500	Pa
Maximum tested negative load	3000	Pa
Hail resistance using ice balls (diameter)	35	mm

Energy Labelling Information			
	Reference Area, A_{sol} (m ²)	Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}	
Vitosol 200-FM SH2G	2.56	Collector efficiency (η_{col})	53 %
		Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2013.	
		Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}	
		Zero-loss efficiency (η_0)	0.745 --
		First-order coefficient (a_1)	3.95 W/(m ² K)
		Second-order coefficient (a_2)	0.033 W/(m ² K ²)
		Incidence angle modifier IAM (50°)	0.92 --
		Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.	

DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany

 Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de