TÜVRheinland®
DIN CERTCO
Genau. Richtig.

Summary of EN 12975 Test Results, annex to Solar KEYMARK Certificate				Licence Number	011-7S2560 F
				Issued	2015-07-07

Company holding the	Viessmann Sp. z.o.o.		Country	Poland	
Brand (optional)	-		Website	-	
Street, street number	ul. Karkonoska 65		E-mail	GorD@viessmann.com	
Postal Code / City, province	53-015	Wroclaw	Tel/Fax	48	713607-125 / -

Collector Type (flat plate glazed/un-glazed; evacuate tubular)	Flat plate collector - glazed
Thermal / photo voltaic hybid collector? (PVT collector)	No
Integration in the roof possible ? (manufacturers declaration)	Yes

	Aperture area (Aa)	Gross length	Gross width	Gross height	Gross area (AG)	Power output per collector module G = 1000 W/m², Tm-Ta				
						0 K	10 K	30 K	50 K	70 K
Collector name	m²	mm	mm	mm	m²	W	W	W	W	W
DIS 20 AL-CU	1.87	1 988	1 006	85	2.00	1 583	1 510	1 345	1 156	944

Performance test method	Glazed liquid heating collector - steady state - indoor									
Performance parameters related to aperture	η0	a1	a2							
Units	-	W/(m²K)	W/(m²K²)							
Test results - Flow rate and fluid see note 1	0.849	3.778	0.016							

Bi-directional incidence angle	No	*Kϑ values are obligatory for 50°.*								
Incidence angle modifiers Kθ(θ)	Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
	Kθ(θ)	1.00	0.99	0.97	0.93	0.88	0.78	0.58	-	0.00
Incidence angle modifier not bi-directional - leave fields blank										

Stagnation temperature - Weather conditions see note 2	Tstg	190.3	°C
Effective thermal capacity	ceff = C/Ag	7.54	kJ/(m²K)
Max. intende operation temperature - see note 3	Tmax,op	208	°C
Max. operation pressure - see note 3	pmax,op	600	kPa

Pressure drop table - for a collector family, the values shall be for the module with highest ΔP per m² aperture area

Flow rate	kg/(s m²)									
Pressure drop, ΔP	Pa									

Optional weather data	Location		Link
Testing Laboratory	TÜV Energie und Umwelt GmbH		
Website	www.eco-tuv.de		
Test report id. number	21228373.001	Date of test report	2015.07.07
During the test GDIF/GTOT was always between	0.11 and 0.88		

Comments of testing laboratory:

Note 1	Flow rate	0.024	kg/(s m²)	Fluid	Water
Note 2	Irradiance, G = 1000 W/m²; Ambient temperature , Ta=30 °C				
Note 3	Given by manufacturer				

TÜV Rheinland Energie und Umwelt GmbH
Am Grauen Stein
D - 51105 Köln

Datasheet version: 4.05, 2013-11-07

TÜVRheinland®
DIN CERTCO
Genau. Richtig.

Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate	Licence Number	011-7S2560 F
	Issued	07.07.2015

Annual collector output kWh/module

Collector name	Location and collector temperature (Tm)											
	Athens			Davos			Stockholm			Würzburg		
	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
DIS 20 AL-CU	2 402	1 713	1 113	1 836	1 269	796	1 346	884	536	1 457	947	565

Collector mounting: Fixed or tracking	Fixed; slope = latitude - 15° (rounded to nearest 5°)

Overview of locations

Location	Latitude °	Gtot kWh/m²	Ta °C	Collector orientation or tracking mode
Athens	38	1 765	18.5	South, 25°
Davos	47	1 714	3.2	South, 30°
Stockholm	59	1 166	7.5	South, 45°
Würzburg	50	1 244	9.0	South, 35°

Gtot	Annual total irradiation on collector plane	kWh/m²
Ta	Mean annual ambient air temperature	°C
Tm	Constant collector operating temperature (mean of in- and outlet temperatures)	°C

The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool ScenoCalc. The collector output is calculated hour by hour according to the efficiency parameters from the Keymark test using constant collector operating temperature (Tm). A detailed description of the calculations is available at http://www.sp.se/en/index/services/solar/ScenoCalc/Sidor/default.aspx.

DIN CERTCO ● Alboinstraße 56 ● 12103 Berlin, Germany
Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de

Datasheet version: 4.05, 2013-11-07
ScenoCalc version: Ver. 4.05 (Nov, 2013)