

Holder/Issued to/Manufacturer

Apricus Solar Co., Ltd.

19 Pu Si Road, Pukou New & High Tech Development Zone, Nanjing, China, 210061

Product name and description

Vacuum tube solar thermal collectors for water heating.
For technical information see Appendix (2 pages).

Models: ETC-CPC-8 ETC-CPC-15 ETC-CPC-18
 ETC-CPC-20 ETC-CPC-24

Performance specification

The product is found to comply with the requirements in EN 12975-1:2006+A1:2010 Solar collectors, Part 1: General requirements and the Specific CEN Keymark Scheme Rules for Solar Thermal Products and are based on test results according to EN 12975-2:2006 Solar collectors Part 2: Test methods.

Marking

Products conforming to this certificate shall be marked in accordance with the requirements in the Specific CEN Keymark Scheme Rules for Solar Thermal Products. The marking shall, together with the Keymark logo, show the identification code of the empowered certification body (RISE Research Institutes of Sweden AB, No. 012), also see CEN-CENELEC Internal Regulations Part 4 Certification, Annex A.

Validity

This certificate is valid until 2024-01-20 provided that the conditions in the Solar Keymark Rules are fulfilled and the standard or rules are not modified significantly. The validity of the certificate can be checked in the database, see Solar Keymark website <http://www.solarkeymark.org>.

Miscellaneous

The manufacturer's factory production control procedures are under surveillance by the responsibility of RISE. RISE certification rules SPCR 402 for Keymark – Solar Thermal Products applies.

Johan Åkesson

Magnus Sturesson

Certificate No. SC0064-19 | issue 1 | 2019-02-21


RISE Research Institutes of Sweden AB | Certification
Box 857, SE-501 15 Borås, Sweden
Phone: +46 10-516 50 00
certifiering@ri.se | www.ri.se

2017-08-08



012



Annex to Solar Keymark Certificate						Licence Number		SC0064-19								
						Date issued		2019-02-21								
						Issued by		RISE								
Licence holder			APRICUS SOLAR CO.,LTD			Country		China								
Brand (optional)			WAMBAT			Web		www.apricus.com								
Street, Number			19 Pu Si Road, Pukou New & High Tech Development Zone			E-mail		service@apricus.com								
Postcode, City			210061, Nanjing			Tel		+86 025-58649133								
Collector Type						Evacuated tubular collector										
Collector name						Power output per collector										
						Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$										
						0 K	10 K	30 K	50 K	70 K	93 K					
						mm	m ²	mm	mm	m ²	W	W	W	W	W	W
ETC-CPC-8						133	1,74	1 917	910	1,41	938	917	869	816	757	682
ETC-CPC-15						133	3,22	1 917	1 680	2,72	1 733	1 693	1 605	1 506	1 398	1 259
ETC-CPC-18						133	3,85	1 917	2 010	3,28	2 073	2 025	1 920	1 802	1 672	1 506
ETC-CPC-20						133	4,28	1 917	2 230	3,66	2 300	2 247	2 130	1 999	1 855	1 671
ETC-CPC-24						133	5,12	1 917	2 670	4,41	2 753	2 690	2 550	2 394	2 221	2 000
Power output per m ² gross area											538	526	498	468	434	391
Performance parameters test method						Steady state - outdoor										
Performance parameters (related to A _G)						η_0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd	
Units						-	W/(m ² K)	W/(m ² K ²)	J/(m ³ K)	-	J/(m ² K)	s/m	W/(m ² K ⁴)	W/(m ² K ⁴)	-	
Test results						0,540	1,21	0,004	0,000	0,000	0,000	0,000	0,000	0,000	0,98	
Incidence angle modifier test method						Steady state - outdoor										
Incidence angle modifier						Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°	
Transversal						$K_{\theta T, coll}$	1,02	1,03	1,04	1,05	1,12	1,18	0,79	0,39	0,00	
Longitudinal						$K_{\theta L, coll}$	1,00	0,99	0,99	0,97	0,95	0,91	0,83	0,57	0,00	
Heat transfer medium for testing						Water-Glycole										
Flow rate for testing (per gross area, A _G)						dm/dt	0,016	kg/(sm ²)								
Maximum temperature difference during thermal performance test						$(\vartheta_m - \vartheta_a)_{max}$	63,24	K								
Standard stagnation temperature (G = 1000 W/m ² ; $\vartheta_a = 30$ °C)						ϑ_{stg}	280	°C								
Maximum operating temperature						$\vartheta_{max, op}$	120	°C								
Maximum operating pressure						$p_{max, op}$	1000	kPa								
Testing laboratory						Intertek Testing Services Shenzhen Ltd. Guangzhou			http://www.intertek.com							
Test report(s)						190108031GZU-001			Dated			2019.01.31				
Comments of testing laboratory						Datashet version: 6.0, 2018-10-30										
The "negative pressure test of the collector" according to EN12975-2:2006, 5.9.2 was not performed.																
Tests were performed based on EN 12975-2:2006.																
<p>RISE Research Institutes of Sweden AB Certification Box 857, SE-501 15 Borås, Sweden, Phone: +46 10-516 50 00, certifiering@ri.se www.ri.se</p>																

Annex to Solar Keymark Certificate Supplementary Information	Licence Number	SC0064-19
	Issued	2019-02-21

Annual collector output in kWh/collector at mean fluid temperature ϑ_m													
Collector name	Standard Locations	Athens			Davos			Stockholm			Würzburg		
	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
ETC-CPC-8		1 633	1 406	1 180	1 374	1 161	961	991	813	654	1 069	878	704
ETC-CPC-15		3 015	2 596	2 179	2 538	2 145	1 775	1 830	1 502	1 208	1 974	1 622	1 300
ETC-CPC-18		3 607	3 106	2 606	3 036	2 566	2 123	2 189	1 797	1 445	2 361	1 940	1 555
ETC-CPC-20		4 002	3 446	2 891	3 369	2 847	2 356	2 428	1 994	1 603	2 619	2 153	1 725
ETC-CPC-24		4 791	4 125	3 462	4 033	3 408	2 821	2 907	2 387	1 919	3 136	2 577	2 065
Annual output per m ² gross area		936	806	676	788	666	551	568	466	375	613	504	404
Fixed or tracking collector	Fixed (slope = latitude - 15°; rounded to nearest 5°)												
Annual irradiation on collector plane	1765 kWh/m ²			1714 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²			
Mean annual ambient air temperature	18,5°C			3,2°C			7,5°C			9,0°C			
Collector orientation or tracking mode	South, 25°			South, 30°			South, 45°			South, 35°			

The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.0 (October 2018). A detailed description of the calculations is available at www.solarkeymark.org/scenocalc

Additional Information	
Collector heat transfer medium	Water-Glycole
The collector is deemed to be suitable for roof integration	No
The collector was tested successfully under the following conditions:	
Climate class (A+, A, B or C)	C
G (W/m ²) >	800
ϑ_a (°C) >	10
H_x (MJ/m ²) >	420
Maximum tested positive load	2860 Pa
Maximum tested negative load	-
Hail resistance using steel ball (maximum drop height)	0,8 m

Additional collector attribute(s)	
<input type="checkbox"/> Using external power source(s) for normal operation	<input type="checkbox"/> Active or passive measure(s) for self-protection
<input type="checkbox"/> Co-generating thermal and electrical power	<input type="checkbox"/> Wind and/or infrared sensitive collector(s) (WISC)
<input type="checkbox"/> Façade collector(s)	

Energy Labelling Information		
	Reference Area, A_{sol} (m ²)	Hydraulic Designation Code
ETC-CPC-8	1,74	1-H-12S-C:19.3,985-D
ETC-CPC-15	3,22	1-H-12S-C:19.3,1755-D
ETC-CPC-18	3,85	1-H-12S-C:19.3,2085-D
ETC-CPC-20	4,28	1-H-12S-C:19.3,2305-D
ETC-CPC-24	5,12	1-H-12S-C:19.3,2745-D

Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}	Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}		
Collector efficiency (η_{col})	48%	Zero-loss efficiency (η_0)	0,54
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.	First-order coefficient (a_1)	1,21	W/(m ² K)
	Second-order coefficient (a_2)	0,004	W/(m ² K ²)
	Incidence angle modifier IAM (50°)	1,01	--
	Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.		