

Annex to Solar Keymark Certificate					Licence Number		011-7S2712 F							
					Date issued		2022-01-17							
					Issued by		DIN CERTCO							
Licence holder		FK Solartechnik GmbH			Country		Germany							
Brand (optional)					Web		www.fk-solartechnik.de							
Street, Number		Industriepark 9			E-mail		info@fksolar.de							
Postcode, City		D- 01968 Senftenberg			Tel		+49 3573 8067-25							
Collector Type					Flat plate collector									
Collector name					Power output per collector									
					Gb = 850 W/m ² , Gd = 150 W/m ² & u = 1.3 m/s $\vartheta_m - \vartheta_a$									
					0 K	10 K	30 K	50 K	70 K	88 K				
					W	W	W	W	W	W				
Basic Comfort					2.32	2 037	1 137	80	1 679	1 589	1 396	1 183	953	729
Power output per m² gross area					725	686	603	511	411	315				
Performance parameters test method		Steady state - indoor												
Performance parameters (related to A_G)		η_0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd			
Units		-	W/(m ² K)	W/(m ² K ²)	J/(m ³ K)	-	J/(m ² K)	s/m	W/(m ² K ⁴)	W/(m ² K ⁴)	-			
Test results		0.736	3.78	0.010			4 770				0.90			
Incidence angle modifier test method		Quasi dynamic - outdoor												
Incidence angle modifier		Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°			
Transversal		K _{GT, coll}	1.00	0.99	0.98	0.96	0.94	0.88	0.78	0.45	0.00			
Longitudinal		K _{GL, coll}	1.00	0.99	0.98	0.96	0.94	0.88	0.78	0.45	0.00			
Heat transfer medium for testing					Water									
Flow rate for testing (per gross area, A_G)					dm/dt	0.020	kg/(sm ²)							
Maximum temperature difference during thermal performance test					($\vartheta_m - \vartheta_a$) _{max}	58	K							
Standard stagnation temperature (G = 1000 W/m²; $\vartheta_a = 30$ °C)					ϑ_{stg}	200	°C							
Maximum operating temperature					$\vartheta_{max, op}$	100	°C							
Maximum operating pressure					p _{max, op}	1000	kPa							
Testing laboratory		ISFH CalTeC			https://isfh.de/									
Test report(s)		005-22/B			Dated		14.01.2022							
Comments of testing laboratory					Ver. 6.2 (13.01.2022)									
					Institut für Solarenergieforschung GmbH Am Ohrberg 1 D-31880 Emmerthal Tel.: 05151/999-100 Fax: 05151/999-500									
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de														

Annex to Solar Keymark Certificate		Licence Number		011-7S2712 F													
Supplementary Information		Issued		2022-01-17													
Gross Thermal Yield in kWh/collector at mean fluid temperature ϑ_m																	
	Standard Locations	Athens			Davos			Stockholm			Würzburg						
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C				
Basic Comfort		2 656	1 840	1 169	1 982	1 336	818	1 466	932	549	1 596	1 004	582				
Gross Thermal Yield per m ² gross area		1 147	794	505	856	577	353	633	402	237	689	434	251				
Annual efficiency, η_a		65%	45%	29%	53%	35%	22%	54%	34%	20%	55%	35%	20%				
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)															
Annual irradiation on collector plane		1765 kWh/m ²			1630 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²						
Mean annual ambient air temperature		18.5°C			3.2°C			7.5°C			9.0°C						
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°						
The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.2 (13.01.2022). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/																	
Additional Information																	
Collector heat transfer medium											Water-Glycole						
The collector is deemed to be suitable for roof integration											No						
The collector was tested successfully under the following conditions:																	
Climate class (A+, A, B or C)											A		--				
G (W/m ²) >		1000		ϑ_a (°C) >		20		H _x (MJ/m ²) >		600							
Maximum tested positive load											3030		Pa				
Maximum tested negative load											2800		Pa				
Hail resistance using steel ball (maximum drop height)											2		m				
Additional collector attribute(s)																	
Using external power source(s) for normal operation				No		Active or passive measure(s) for self-protection				No							
Co-generating thermal and electrical power				No		Façade collector(s)				No							
Energy Labelling Information						Additional Informative Technical Data											
		Reference Area, A _{sol} (m ²)				Hydraulic Designation Code				Aperture Area, A _a (m ²)							
Basic Comfort		2.32				1-VH-12S-A:11.3;16250				2.13							
Data required for CDR (EU) No 811/2013 - Reference Area						Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}											
Collector efficiency (η_{col})		56%				Zero-loss efficiency (η_0)				0.72				--			
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.						First-order coefficient (a ₁)				3.78				W/(m ² K)			
						Second-order coefficient (a ₂)				0.010				W/(m ² K ²)			
						Incidence angle modifier IAM (50°)				0.92				--			
Remark: The data given in this section are related to collector reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.																	
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany																	
Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de																	