Summary of EN 12975 Test Results, annex to Solar KEYMARK Certificate

Certificate No.	**011-7S2138 F**
Date of issue	13.05.2013

Company	Vaillant GmbH	**Country**		Deutschland
Brand (optional)		**Website**		www.vaillant.com
Street, number	Berghauser Str.40	**E-mail**		Marc.imann@vaillant.de
Postal Code	42859	**Tel.**	+49	2 191 182 043
City	Remscheid	**Fax**	+49	21 911 872 043

Collector Type (flat plate / evacuate tubular / un-glazed)	Flat plate collector
Integration in the roof possible ?	Yes

Collector name	Aperture area (Aa) [m²]	Gross length [mm]	Gross width [mm]	Gross height [mm]	Gross area (Ag) [m²]	Power output per collector unit G = 1000 W/m² Tm-Ta : 0 K [W]	10 K [W]	30 K [W]	50 K [W]	70 K [W]
VFK 112*	1.92	1 988	1 041	90	2.07	1 507	1 433	1 272	1 092	894

Collector efficiency parameters related to aperture area (Aa) Type of fluid and flow rate see note 1	η_{0a}	0.785	-
	a_{1a}	3.722	W/(m²K)
	a_{2a}	0.012	W/(m²K²)
Stagnation temperature - Weather conditions see note 2	t_{stg}	203	°C
Effective thermal capacity	$c_{eff} = C/A_a$	9.54	kJ/(m²K)
Max. operation pressure - see note 3	p_{max}	1000	kPa

Incidence angle modifiers $K_\theta(\theta)$	G_{DIF}/G_{TOT} min	G_{DIF}/G_{TOT} max	θ_T / θ_L	50°	*10°*	*20°*	*30°*	*40°*	*60°*	*70°*
	-	-	$K_\theta(\theta_T)$	0.94	1.00	0.99	0.98	0.97	0.90	0.80
	-	-	$K_\theta(\theta_L)$	0.94	1.00	0.99	0.98	0.97	0.90	0.80

G_{DIF}/G_{TOT}: min&max - while measuring

Optional values

Testing Laboratory	TZS, ITW University of Stuttgart
Website	www.tzs.uni-stuttgart.de
Test report id. number	12COL1079OEM12, 12COL1079QOEM12
Date of test report	13.05.2013
Perf. test method	EN 12975-2 6.1.4 (outdoor)

Comments of testing laboratory :

* dimensions according to manufacturer

Note 1	**Fluid**	Water	**Flow rate**	0.020	kg/s per m²
Note 2	**Irradiance, Gs=1000 W/m²** **Ambient temperature , Ta=30 °C**				
Note 3	**Given by manufacturer**				

Forschungs- und Testzentrum für Solaranlagen, Institut für Thermodynamik und Wärmetechnik, Universität Stuttgart, Pfaffenwaldring 6, 70550 Stuttgart (Vaihingen)

VERSION 3.6, 2012.01.13

Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate	Certificate No.	011-7S2138 F
	Issued	13.05.2013

Annual collector output kWh

Collector name	Location and collector temperature (Tm)														
	Athens			Davos			Stockholm			Würzburg					
	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C			
VFK 112*	2 443	1 749	1 154	1 989	1 372	859	1 368	897	546	1 489	973	583			

Collector mounting: Fixed or tracking	Fixed; slope = latitude - 15° (rounded to nearest 5°)

Overview of locations

Location	Latitude °	Gtot kWh/m²	Ta °C	Collector orientation or tracking mode
Athens	38	1 765	18.5	South, 25°
Davos	47	1 714	3.2	South, 30°
Stockholm	59	1 166	7.5	South, 45°
Würzburg	50	1 244	9.0	South, 35°

Gtot	Annual total irradiation on collector plane	kWh/m²
Ta	Mean annual ambient air temperature	°C
Tm	Constant collector operating temperature (mean of in- and outlet temperatures)	°C

Calculation of the annual collector performance is done by the official Solar Keymark spreadsheet tool. Hour by hour the collector output is calculated according to the efficiency parameters from the Keymark test using constant collector operating temperature (Tm). Detailed description with all equations used is available from the Solar Keymark web site (direct link: http://www.estif.org/solarkeymark/annexb1.php)

DIN CERTCO ● Alboinstraße 56 ● 12103 Berlin
Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de

Datasheet version:
VERSION 3.6, 2012.01.13
Calculation program version:
3.07, October 2011 (SP)