


Annex to Solar Keymark Certificate - Summary of EN ISO 9806:2013 Test Results					Licence Number		TSU 001-16/D																	
					Date issued		2016-10-03																	
					Issued by		TSU Piešťany, š.p.																	
Licence holder		ELVOSOLAR a.s.			Country		Slovak republic																	
Brand (optional)					Web		www.elvosolar.sk																	
Street, Number		Agátová 22, P.O.BOX 108			E-mail		ancic@elvosolar.sk																	
Postcode, City		SK-841 01 Bratislava			Tel		+421 905609462																	
Collector Type					Flat plate collector, glazed																			
Collector name					Gross area (A_G)		Gross length		Gross width		Gross height		Power output per collector Gb = 850 W/m ² ; Gd = 150 W/m ² $\vartheta_m - \vartheta_a$											
					m ²		mm		mm		mm		0 K		10 K		30 K		50 K		70 K		90 K	
ELVOSOLAR TS300-2.03					2,03		2 009		1 009		75		1 445		1 379		1 234		1 074		899		708	
Power output per m² gross area					712		679		608		529		443		349									
Performance parameters test method					Steady state - outdoor																			
Performance parameters (related to AG)					$\eta_{0,hem}$		a1		a2															
Units					-		W/(m ² K)		W/(m ² K ²)															
Test results					0,712		3,180		0,010															
Incidence angle modifier test method					Steady state - outdoor																			
Bi-directional incidence angle modifiers					No																			
Incidence angle modifier					Angle		10°		20°		30°		40°		50°		60°		70°		80°		90°	
Transversal					$K_{AT, coll}$								0,95										0,00	
Longitudinal					$K_{GL, coll}$								0,95										0,00	
Heat transfer medium for testing					Water																			
Flow rate for testing (per gross area, A_G)					dm/dt		0,010		kg/(sm ²)															
Maximum temperature difference for thermal performance calculations					$(\vartheta_m - \vartheta_a)_{max}$		90		K															
Standard stagnation temperature ($G = 1000$ W/m²; $\vartheta_a = 30$ °C)					ϑ_{sta}		196		°C															
Effective thermal capacity, incl. fluid (per gross area, A_G)					C/m ²		6,32		kJ/(Km ²)															
Maximum operating temperature					$\vartheta_{max, op}$		100		°C															
Maximum operating pressure					$p_{max, op}$		600		kPa															
Testing laboratory					Technický skúšobný ústav Piešťany, š.p.							http://www.tsu.sk												
Test report(s)					120700004/1/P(D5) 110700001/1/PQ(D5)							Dated		4.3.2016		4.3.2016								
Comments of testing laboratory					Performance parameters - complete re-evaluation of the test data of the previous test (according to EN 12975-2:2006) taking into account gross area.							Datashet version: 5.01, 2016-03-01												
												 TECHNICKÝ SKÚŠOBNÝ ÚSTAV PIEŠŤANY, š.p. Krajinská cesta 2929/9 92101 PIEŠŤANY -316/3-												
Technický skúšobný ústav Piešťany, š.p.																								
Address: Krajinská cesta 2929/9, 92101 Piešťany, Slovak Republic																								
Phone: +421 33 79 57 111, Fax: +421 33 77 23 716, E-mail: sv@tsu.sk, web: www.tsu.eu																								

Annex to Solar Keymark Certificate Supplementary Information	Licence Number	TSU 001-16/D
	Issued	2016-10-03

Annual collector output in kWh/collector at mean fluid temperature ϑ_m, based on ISO 9806:2013 test results													
Standard Locations		Athens			Davos			Stockholm			Würzburg		
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
ELVOSOLAR TS300-2.03		2 335	1 707	1 164	1 793	1 277	843	1 319	888	563	1 432	961	599
Annual output per m ² gross area		1 150	841	573	883	629	415	650	437	277	705	474	295
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m ²			1714 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²		
Mean annual ambient air temperature		18,5°C			3,2°C			7,5°C			9,0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 5.01 (March 2016). A detailed description of the calculations is available at www.solarkeymark.org/scenocalc

Additional Information		
Collector heat transfer medium	Water-Glycole	
Hybrid Thermal and Photo Voltaic collector	No	
The collector is deemed to be suitable for roof integration	No	
The collector was tested successfully according to EN ISO 9806:2013 under the following conditions:		
Climate class (A, B or C)	C	--
Maximum tested positive load	1000	Pa
Maximum tested negative load	1000	Pa
Hail resistance using steel ball (maximum drop height)		m

Energy Labelling Information			
	Reference Area, A_{sol} (m ²)	Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}	
ELVOSOLAR TS300-2.03	2,03	Collector efficiency (η_{col})	57 %
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2013.			
Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}			
		Zero-loss efficiency (η_0)	0,712 --
		First-order coefficient (a_1)	3,18 W/(m ² K)
		Second-order coefficient (a_2)	0,010 W/(m ² K ²)
		Incidence angle modifier IAM (50°)	0,95 --
Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.			

Technický skúšobný ústav Piešťany, š.p.

Address: Krajinská cesta 2929/9, 92101 Piešťany, Slovak Republic
Phone: +421 33 79 57 111, Fax: +421 33 77 23 716, E-mail: sv@tsu.sk, web: www.tsu.eu