


Annex to Solar Keymark Certificate					Licence Number		011-7S1284 F				
					Date issued		2020-09-07				
					Issued by		DIN CERTCO				
Licence holder		Sonnenkraft GmbH			Country		Austria				
Brand (optional)		-			Web		www.sonnenkraft.com				
Street, Number		Solarstrasse 1			E-mail		office@sonnenkraft.com				
Postcode, City		A – 9300 St. Veit/Glan			Tel		+43 (0) 4212 45010				
Collector Type					Flat plate collector						
Collector name					Power output per collector						
					Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$						
					0 K	10 K	30 K	50 K	70 K	110 K	
					m ²	mm	mm	mm	W	W	W
SKR500L					2.58	1 240	2 079	95	1 845	1 753	1 557
Power output per m ² gross area					715	679	603	522	435	244	
Performance parameters test method		Quasi dynamic									
Performance parameters (related to A _G)		η _{0, b}	a1	a2	a3	a4	a5	a6	a7	a8	Kd
Units		-	W/(m ² K)	W/(m ² K ²)	J/(m ³ K)	-	J/(m ² K)	s/m	W/(m ² K ⁴)	W/(m ² K ⁴)	-
Test results		0.717	3.51	0.007	0.000	0.00	8 581	0.000	0.00	0.0	0.98
Incidence angle modifier test method		Quasi dynamic - outdoor									
Incidence angle modifier		Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
Transversal		K _{θT, coll}	1.00	1.00	1.00	0.99	0.96	0.90	0.71	0.36	0.00
Longitudinal		K _{θL, coll}	1.00	1.00	1.00	0.99	0.96	0.90	0.71	0.36	0.00
Heat transfer medium for testing		Water									
Flow rate for testing (per gross area, A _G)		dm/dt		0.020		kg/(sm ²)					
Maximum temperature difference during thermal performance test		(ϑ _m - ϑ _a) _{max}		80		K					
Standard stagnation temperature (G = 1000 W/m ² ; ϑ _a = 30 °C)		ϑ _{stg}		200		°C					
Maximum operating temperature		ϑ _{max, op}		-		°C					
Maximum operating pressure		p _{max, op}		1000		kPa					
Testing laboratory		Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung (IGTE)					http://www.igte.uni-stuttgart.de				
Test report(s)		20COL1536OEM01 20COL1535QOEM01					Dated		07.09.2020 07.09.2020		
Comments of testing laboratory		Datashet version: 6.1, 2019-09-26									
Thermal performance parameters are taken from 20COL1536QOEM01											
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de											

Annex to Solar Keymark Certificate		Licence Number																	
Supplementary Information		011-7S1284 F																	
		Issued																	
		2020-09-07																	
Annual collector output in kWh/collector at mean fluid temperature ϑ_m																			
	Standard Locations	Athens			Davos			Stockholm			Würzburg								
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C						
SKR500L		3 029	2 179	1 472	2 304	1 622	1 069	1 690	1 123	708	1 847	1 221	758						
Annual output per m ² gross area		1 174	845	570	893	629	414	655	435	274	716	473	294						
Annual efficiency, η_a		67%	48%	32%	55%	39%	25%	56%	37%	24%	58%	38%	24%						
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)																	
Annual irradiation on collector plane		1765 kWh/m ²			1630 kWh/m ²			1166 kWh/m ²			1244 kWh/m ²								
Mean annual ambient air		18.5°C			3.2°C			7.5°C			9.0°C								
Collector orientation or tracking		South, 25°			South, 30°			South, 45°			South, 35°								
The collector is operated at constant temperature ϑ_m (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.1 (September 2019). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/																			
Additional Information																			
Collector heat transfer medium											Water-Glycole								
The collector is deemed to be suitable for roof integration											No								
The collector was tested successfully under the following conditions:																			
Climate class (A+, A, B or C)											A		--						
G (W/m ²) >		1000		ϑ_a (°C) >		20		H _x (MJ/m ²) >			600								
Maximum tested positive load											3000		Pa						
Maximum tested negative load											2800		Pa						
Hail resistance using steel ball (maximum drop height)											2		m						
Additional collector attribute(s)																			
<input type="checkbox"/> Using external power source(s) for normal operation				<input type="checkbox"/> Active or passive measure(s) for self-protection															
<input type="checkbox"/> Co-generating thermal and electrical power				<input type="checkbox"/> Façade collector(s)															
Energy Labelling Information						Additional Informative Technical Data													
Reference Area, A _{sol} (m ²)						Hydraulic Designation Code				Aperture Area, A _a (m ²)									
SKR500L						2.58				1-H-1234S-7.2,22056-16.6,2071-D				2.26					
Data required for CDR (EU) No 811/2013 - Reference Area						Data required for CDR (EU) No 812/2013 - Reference Area A _{sol}													
Collector efficiency (η_{col})						56%						Zero-loss efficiency (η_0)		0.72		--			
Remark: Collector efficiency (η_{col}) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m ² , expressed in % and rounded to the nearest integer. Deviating from the regulation η_{col} is based on reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.						First-order coefficient (a ₁)						3.51		W/(m ² K)					
						Second-order coefficient (a ₂)						0.007		W/(m ² K ²)					
						Incidence angle modifier IAM (50°)						0.98		--					
												Remark: The data given in this section are related to collector reference area (A _{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.							
DIN CERTCO • Alboinstraße 56 • 12103 Berlin, Germany																			
Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de																			