


<b>Summary of EN 12975 Test Results, annex to Solar KEYMARK Certificate</b>						<b>Licence Number</b>		<b>011-7S2609 F</b>							
						<b>Issued</b>		2016-04-26							
<b>Company holding the</b>			Solimpeks Solar Energy Corp.			<b>Country</b>		Turkey							
<b>Brand (optional)</b>						<b>Website</b>		www.solimpeks.com							
<b>Street, street number</b>			Fevzi Çakmak Mah. 10753 Sk. No:3			<b>E-mail</b>		yusuf.akay@solimpeks.com							
<b>Postal Code / City, province</b>			42050 Karatay Konya			<b>Tel/Fax</b>		+90 444060 -2 / -8							
<b>Collector Type (flat plate glazed/un-glazed; evacuate tubular)</b>						Flat plate collector - glazed									
<b>Thermal / photo voltaic hybrid collector? (PVT collector)</b>						No									
<b>Integration in the roof possible ? (manufacturers declaration)</b>						No									
						<b>Power output per collector module</b>									
						Gb = 850 W/m <sup>2</sup> ; Gd = 150 W/m <sup>2</sup>									
						Tm-Ta									
						0 K	10 K	30 K	50 K	70 K					
<b>Collector name</b>						W	W	W	W	W					
EXCELL ALS						1.88	1958	992	50	1.94	1479	1406	1232	1021	771
<b>Performance test method</b>						Liquid heating collector - quasi-dynamic - outdoor									
<b>Performance parameters related to aperture area</b>						$\eta_{0b}$	c1	c2	c3	c4	c6	K $\theta$ d			
<b>Units</b>						-	W/(m <sup>2</sup> K)	W/(m <sup>2</sup> K <sup>2</sup> )	J/(m <sup>3</sup> K)	-	s/m	-			
<b>Test results - Flow rate and fluid see note 1</b>						0.795	3.626	0.025	0.000	0.000	0.000	0.930			
<b>Bi-directional incidence angle modifiers?</b>						No <i>K<math>\theta</math> values are obligatory for 50°.</i>									
<b>Incidence angle modifiers K<math>\theta</math>(<math>\theta</math>)</b>						Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
						K $\theta$ ( $\theta$ )	1.00	0.99	0.98	0.95	0.91	0.85	0.70	0.26	0.00
<b>Incidence angle modifier not bi-directional - leave fields blank</b>															
<b>Stagnation temperature - Weather conditions see note 2</b>						Tstg		169		°C					
<b>Effective thermal capacity</b>						ceff = C/Ag		9.981		kJ/(m <sup>2</sup> K)					
<b>Max. intended operation temperature - see note 3</b>						Tmax,op		90		°C					
<b>Max. operation pressure - see note 3</b>						pmax,op		860		kPa					
<b>Pressure drop table - for a collector family, the values shall be for the module with highest <math>\Delta P</math> per m<sup>2</sup> aperture area</b>															
<b>Flow rate</b>	kg/(s m <sup>2</sup> )	-	-	-	-	-	-	-	-	-	-	-			
<b>Pressure drop, <math>\Delta P</math></b>	Pa	-	-	-	-	-	-	-	-	-	-	-			
<b>Optional weather data</b>						Location		Link							
<b>Testing Laboratory</b>						TZS, ITW University Stuttgart									
<b>Website</b>						http://www.itw.uni-stuttgart.de									
<b>Test report id. number</b>						15COL1292, 15COL1292Q			<b>Date of test report</b>		2015.12.10				
<b>During the test GDIF/GTOT was always between</b>						0		and		1					
<b>Comments of testing laboratory:</b>															
This data sheet replaces the data sheet issued on 10.12.2015. Effective thermal capacity was corrected to 9.981 kJ/(m <sup>2</sup> K).															
<b>Note 1</b>	<b>Flow rate</b>	0.020	kg/(s m <sup>2</sup> )	<b>Fluid</b>	Water										
<b>Note 2</b>	Irradiance, G = 1000 W/m <sup>2</sup> ; Ambient temperature , Ta=30 °C														
<b>Note 3</b>	Given by manufacturer														
						 Forschungs- und Testzentrum für Solartechnik Institut für Photovoltaik, Fachbereich 08 Universität Stuttgart Pfaffenwaldring 6, 70569 Stuttgart (Vaihingen)									
						Datasheet version: 4.06, 2014-01-15									
DIN CERTCO • Alboinstraße 56 • 12103 Berlin Tel: +49 30 7562-1131 • Fax: +49 30 7562-1141 • E-Mail: info@dincertco.de • www.dincertco.de															



Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate	Licence Number	011-7S2609 F
	Issued	26.04.2016

Annual collector output kWh/module															
Collector name	Location and collector temperature (Tm)														
	Athens			Davos			Stockholm			Würzburg					
	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C			
EXCELL ALS	2 343	1 628	973	1 763	1 152	631	1 302	813	438	1 421	881	466			

Collector mounting: Fixed or tracking Fixed; slope = latitude - 15° (rounded to nearest 5°)

Overview of locations				
Location	Latitude °	Gtot kWh/m²	Ta °C	Collector orientation or tracking mode
Athens	38	1 765	18.5	South, 25°
Davos	47	1 714	3.2	South, 30°
Stockholm	59	1 166	7.5	South, 45°
Würzburg	50	1 244	9.0	South, 35°

Gtot	Annual total irradiation on collector plane	kWh/m²
Ta	Mean annual ambient air temperature	°C
Tm	Constant collector operating temperature (mean of in- and outlet temperatures)	°C

The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool ScenoCalc. The collector output is calculated hour by hour according to the efficiency parameters from the Keymark test using constant collector operating temperature (Tm). A detailed description of the calculations is available at <http://www.sp.se/en/index/services/solar/ScenoCalc/Sidor/default.aspx>.