TÜVRheinland®
DIN CERTCO
Precisely Right.

IGTE

Annex to Solar Keymark Certificate		Licence Number	011-7S1277 F
		Date issued	2020-09-07
		Issued by	DIN CERTCO

Licence holder	**Sonnenkraft GmbH**	**Country**	Austria
Brand (optional)	-	**Web**	www.sonnenkraft.com
Street, Number	Solarstrasse 1	**E-mail**	office@sonnenkraft.com
Postcode, City	A – 9300 St. Veit/Glan	**Tel**	+43 (0) 4212 45010

Collector Type	Flat plate collector

Collector name	Gross area (A_G)	Gross length	Gross width	Gross height	Power output per collector Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$					
					0 K	10 K	30 K	50 K	70 K	110 K
	m²	mm	mm	mm	W	W	W	W	W	W
SKR500	2.58	2 079	1 240	95	1 836	1 746	1 548	1 325	1 077	507
Power output per m² gross area					712	677	600	513	417	197

Performance parameters test method	Quasi dynamic									
Performance parameters (related to A_G)	η0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd
Units	-	W/(m²K)	W/(m²K²)	J/(m³K)	-	J/(m²K)	s/m	W/(m²K⁴)	W/(m²K⁴)	-
Test results	0.713	3.36	0.012	0.000	0.00	8 340	0.000	0.00	0.0	0.99

Incidence angle modifier test method		Quasi dynamic - outdoor								
Incidence angle modifier	Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
Transversal	$K_{\theta T,coll}$	1.00	1.00	1.00	0.99	0.97	0.91	0.73	0.37	0.00
Longitudinal	$K_{\theta L,coll}$	1.00	1.00	1.00	0.99	0.97	0.91	0.73	0.37	0.00

Heat transfer medium for testing		Water	
Flow rate for testing (per gross area, A_G)	dm/dt	0.020	kg/(sm²)
Maximum temperature difference during thermal performance test	$(\vartheta_m-\vartheta_a)_{max}$	80	K
Standard stagnation temperature (G = 1000 W/m²; ϑ_a = 30 °C)	ϑ_{stg}	200	°C
Maximum operating temperature	ϑ_{max_op}	-	°C
Maximum operating pressure	$p_{max,op}$	1000	kPa

Testing laboratory	Institut für Gebäudeenergetik, Thermotechnik und Energiespeicherung (IGTE)	http://www.igte.uni-stuttgart.de	
Test report(s)	20COL1535OEM01 20COL1535QOEM01	**Dated**	07.09.2020 07.09.2020

Comments of testing laboratory — Datasheet version: 6.1, 2019-09-26

Thermal performance parameters are taken from test report 20COL1435OEM01

TZS Forschungs- und Testzentrum für Solaranlagen
Institut für Thermodynamik und Wärmetechnik
Universität Stuttgart
Pfaffenwaldring 6, 70550 Stuttgart (Vaihingen)

Annex to Solar Keymark Certificate	Licence Number	011-7S1277 F
Supplementary Information	Issued	2020-09-07

Annual collector output in kWh/collector at mean fluid temperature ϑ_m

Standard Locations	Athens			Davos			Stockholm			Würzburg		
Collector name / ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
SKR500	3 027	2 176	1 432	2 306	1 601	1 010	1 693	1 114	675	1 851	1 212	724
Annual output per m² gross area	1 173	843	555	894	621	391	656	432	262	717	470	281
Annual efficiency, η_a	66%	48%	31%	55%	38%	24%	56%	37%	22%	58%	38%	23%
Fixed or tracking collector	Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane	1765 kWh/m²			1630 kWh/m²			1166 kWh/m²			1244 kWh/m²		
Mean annual ambient air	18.5°C			3.2°C			7.5°C			9.0°C		
Collector orientation or tracking	South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑm (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.1 (September 2019). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/

Additional Information

Collector heat transfer medium					Water-Glycole	
The collector is deemed to be suitable for roof integration					No	
The collector was tested successfully under the following conditions:						
Climate class (A+, A, B or C)					A	--
G (W/m²) >	1000	ϑ_a (°C) >	20	H_x (MJ/m²) >		600
Maximum tested positive load					3000	Pa
Maximum tested negative load					2800	Pa
Hail resistance using steel ball (maximum drop height)					2	m

Additional collector attribute(s)

- ☐ Using external power source(s) for normal operation
- ☐ Active or passive measure(s) for self-protection
- ☐ Co-generating thermal and electrical power
- ☐ Façade collector(s)

Energy Labelling Information

	Reference Area, A_{sol} (m²)
SKR500	2.58

Data required for CDR (EU) No 811/2013 - Reference Area

Collector efficiency (η_{col})	56%

Remark: Collector efficiency (ηcol) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m², expressed in % and rounded to the nearest integer. Deviating from the regulation ηcol is based on reference area (Asol) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.

Additional Informative Technical Data

Hydraulic Designation Code	Aperature Area, A_a (m²)
1-H-1234S-7.2,20440-16.6,1232-D	2.26

Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}

Zero-loss efficiency (η_0)	0.71	--
First-order coefficient (a_1)	3.36	W/(m²K)
Second-order coefficient (a_2)	0.012	W/(m²K²)
Incidence angle modifier IAM (50°)	0.98	--

Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.

DIN CERTCO ● Alboinstraße 56 ● 12103 Berlin, Germany
Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de