Summary of EN 12975 Test Results, annex to Solar KEYMARK Certificate	**Certificate No.**	**OEM 9965/8/1**
	Date of issue	22/6/2018

Company	PROVEEDORA DE MATERIAL SOLAR, S.L.	**Country**		SPAIN
Brand (optional)		**Website**		
Street, number	C/CIRO ALEGRIA 3, POLIGONO INDUSTRIAL GUADALHORCE	**E-mail**		
Postal Code	29004	**Tel.**	+034	952244044
City	MALAGA	**Fax**		

Collector Type (flat plate / evacuate tubular / un-glazed)	Flat plate collector
Integration in the roof possible ?	Yes

Collector name	**Aperture area (Aa)** [m²]	**Gross length** [mm]	**Gross width** [mm]	**Gross height** [mm]	**Gross area (A_G)** [m²]	**Power output per collector unit** G = 1000 W/m² Tm-Ta : 0 K [W]	10 K [W]	30 K [W]	50 K [W]	70 K [W]
Elite 1.5 Blue	1,40	1.530	1.030	80	1,58	1.017	950	811	667	517
Elite 2.0 Blue	1,88	2.030	1.030	80	2,09	1.365	1.275	1.089	895	694
Elite 2.6 Blue	2,37	2.030	1.283	80	2,60	1.721	1.608	1.373	1.129	875

Collector efficiency parameters related to aperture area (Aa) Note 1	η_{0a}	0,73	-
	a_{1a}	4,74	W/(m²K)
	a_{2a}	0,005	W/(m²K²)
Stagnation temperature - Note 2	t_{stg}	153	°C
Effective thermal capacity	$c_{eff} = C/A_a$	10,67	kJ/(m²K)
Max. operation pressure - Note 3	p_{max}	1000	kPa

Incidence angle modifiers $K_\theta(\theta)$	G_{DIF}/G_{TOT}		θ_T / θ_L	50°	*10°*	*20°*	*30°*	*40°*	*60°*	*70°*
	min	max	$K_\theta(\theta_T)$	0,85	*1,00*	*0,99*	*1,00*	*0,97*	*0,73*	*0,81*
	0,28	0,54	$K_\theta(\theta_L)$	0,85	*1,00*	*0,99*	*1,00*	*0,97*	*0,73*	*0,81*
G_{DIF}/G_{TOT}: min&max - while measuring					***Optional values***					

Testing Laboratory	Demokritos
Website	www.solar.demokritos.gr
Test report id. number	4076DE5, 4078DE5, 4084DQ4
Date of test report	23/3/2018, 29/3/2018
Perf. test method	EN 12975-2 6.1.4 (outdoor/außen/extérie

Comments of testing laboratory :

Note 1	**Test conditions**	**Fluid**	Water	**Flow rate**	0,020	kg/s per m²
Note 2	**Irradiance, Gs=1000 W/m²** **Ambient temperature , Ta=30 °C**					
Note 3	**Given by manufacturer**					

Central Offices: Kalavriton 4, 145 64 kifisia, Athens, Tel: +301 6233493-4 , Fax: +301 6233495, http://www.dqshellas.gr, e-mail: ioannisalexiou@dqshellas.gr

Annual collector output based on EN 12975 Test Results, annex to Solar KEYMARK Certificate	Certificate No.	OEM 9965/8/1
	Issued	22/6/2018

Annual collector output kWh / Jährliche Kollektor Leistung kWh / Energie annuelle produite par le capteur

	Location and collector temperature (Tm)														
	Athens			Davos			Stockholm			Würzburg					
Collector name	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
Elite 1.5 Blue	1.495	945	555	1.138	712	407	791	466	261	860	496	272			
Elite 2.0 Blue	2.007	1.269	746	1.529	957	547	1.062	625	350	1.155	667	365			
Elite 2.6 Blue	2.530	1.599	940	1.927	1.206	690	1.339	788	441	1.456	840	460			

Collector mounting: Fixed or tracking /	Fixed; slope = latitude - 15° (rounded to nearest 5°)

Overview of locations

Location	Latitude °	Gtot kWh/m²	Ta °C	**Collector orientation or tracking mode**
Athens	38	1.765	18,5	South, 25°
Davos	47	1.714	3,2	South, 30°
Stockholm	59	1.166	7,5	South, 45°
Würzburg	50	1.244	9,0	South, 35°

Gtot	Annual total irradiation on collector plane	kWh/m²
Ta	Mean annual ambient air temperature	°C
Tm	Constant collector operating temperature (mean of in- and outlet temperatures)	°C

Calculation of the annual collector performance is done by the official Solar Keymark spreadsheet tool. Hour by hour the collector output is calculated according to the efficiency parameters from the Keymark test using constant collector operating temperature (Tm). Detailed description with all equations used is available from the Solar Keymark web site (direct link: http://www.estif.org/solarkeymark/annexb1.php)

Central Offices: Kalavriton 4, 145 64 kifisia, Athens, Tel: +301 6233493-4 , Fax: +301 6233495, http://www.dqshellas.gr, e-mail: ioannisalexiou@dqshellas.gr

Datasheet version:
VERSION 3.4, 30-11-2011
Calculation program version:
3.07 October 2011