TÜVRheinland®
DIN CERTCO
Precisely Right.

Annex to Solar Keymark Certificate		Licence Number	011-7S2993 F
		Date issued	2020-12-04
		Issued by	DIN CERTCO

Licence holder	HEWALEX Sp. z o.o. Sp. k.	Country	Poland	
Brand (optional)	–	Web	www.hewalex.pl	
Street, Number	Slowackiego 33	E-mail	hewalex@hewalex.pl	
Postcode, City	PL 43-502, Czechowice-Dziedzice	Tel	+48	32 214 17 10

Collector Type	Flat plate collector

Collector name	Gross area (A_G)	Gross length	Gross width	Gross height	Power output per collector Gb = 850 W/m2, Gd = 150 W/m2 & u = 1.3 m/s $\vartheta_m - \vartheta_a$					
					0 K	10 K	30 K	50 K	70 K	121 K
	m²	mm	mm	mm	W	W	W	W	W	W
KS2600F MLP ACR	2.62	2'022	1'295	90	1'951	1'829	1'574	1'305	1'021	230
Power output per m² gross area					745	698	601	498	390	88

Performance parameters test method	Steady state - outdoor								
Performance parameters (related to A_G)	η0, b	a1	a2	a3	a4	a5	a6	a7	a8	Kd
Units	-	W/(m²K)	W/(m²K²)	J/(m³K)	-	J/(m²K)	s/m	W/(m²K⁴)	W/(m²K⁴)	-
Test results	0.757	4.58	0.007	0.000	0.00	3'782	0.000	0.00	0.0E+00	0.89

Incidence angle modifier test method		Steady state - outdoor								
Incidence angle modifier	Angle	10°	20°	30°	40°	50°	60°	70°	80°	90°
Transversal	$K_{\theta T,coll}$	1.00	0.99	0.99	0.98	0.95	0.87	0.69	0.38	0.00
Longitudinal	$K_{\theta L,coll}$	1.00	0.99	0.99	0.98	0.95	0.87	0.69	0.38	0.00

Heat transfer medium for testing		Water-Glycole	
Flow rate for testing (per gross area, A_G)	dm/dt	0.020	kg/(sm²)
Maximum temperature difference during thermal performance test	$(\vartheta_m-\vartheta_a)_{max}$	91	K
Standard stagnation temperature (G = 1000 W/m²; ϑ_a = 30 °C)	ϑ_{stg}	180	°C
Maximum operating temperature	$\vartheta_{max\ op}$	180	°C
Maximum operating pressure	$p_{max,op}$	1000	kPa

Testing laboratory	SPF Testing, CH-8640 Rapperswil, Switzerland	www.spf.ch	
Test report(s)	C1842ISO	Dated	04.12.2020

Comments of testing laboratory	Datasheet version: 6.1, 2019-09-26
	SPF INSTITUT FÜR SOLARTECHNIK

Annex to Solar Keymark Certificate	Licence Number	011-7S2993 F
Supplementary Information	Issued	2020-12-04

Annual collector output in kWh/collector at mean fluid temperature ϑ_m

Standard Locations		Athens			Davos			Stockholm			Würzburg		
Collector name	ϑ_m	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C	25°C	50°C	75°C
KS2600F MLP ACR		3'065	2'014	1'213	2'227	1'436	838	1'649	996	559	1'801	1'072	592
Annual output per m² gross area		1'170	769	463	850	548	320	630	380	213	688	409	226
Annual efficiency, η_a		66%	44%	26%	52%	34%	20%	54%	33%	18%	55%	33%	18%
Fixed or tracking collector		Fixed (slope = latitude - 15°; rounded to nearest 5°)											
Annual irradiation on collector plane		1765 kWh/m²			1630 kWh/m²			1166 kWh/m²			1244 kWh/m²		
Mean annual ambient air temperature		18.5°C			3.2°C			7.5°C			9.0°C		
Collector orientation or tracking mode		South, 25°			South, 30°			South, 45°			South, 35°		

The collector is operated at constant temperature ϑm (mean of in- and outlet temperatures). The calculation of the annual collector performance is performed with the official Solar Keymark spreadsheet tool Scenocalc Ver. 6.1 (September 2019). A detailed description of the calculations is available at http://www.estif.org/solarkeymarknew/

Additional Information

Collector heat transfer medium				Water-Glycole	
The collector is deemed to be suitable for roof integration				Yes	
The collector was tested successfully under the following conditions:					
Climate class (A+, A, B or C)				A	--
G (W/m²) >	1000	ϑ_a (°C) >	20	H_x (MJ/m²) >	600
Maximum tested positive load				5400	Pa
Maximum tested negative load				2400	Pa
Hail resistance using ice balls (diameter)				35	mm

Additional collector attribute(s)

- ☐ Using external power source(s) for normal operation
- ☐ Active or passive measure(s) for self-protection
- ☐ Co-generating thermal and electrical power
- ☐ Façade collector(s)

Energy Labelling Information

	Reference Area, A_{sol} (m²)
KS2600F MLP ACR	2.62

Data required for CDR (EU) No 811/2013 - Reference Area A_{sol}

Collector efficiency (η_{col})	55%

Remark: Collector efficiency (ηcol) is defined in CDR (EU) No 811/2013 as collector efficiency of the solar collector at a temperature difference between the solar collector and the surrounding air of 40 K and a global solar irradiance of 1000 W/m², expressed in % and rounded to the nearest integer. Deviating from the regulation ηcol is based on reference area (Asol) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806:2017.

Additional Informative Technical Data

Hydraulic Designation Code	Aperature Area, A_a (m²)
14-V-1234S-A:5,1915-C:16,1300-D	2.47

Data required for CDR (EU) No 812/2013 - Reference Area A_{sol}

Zero-loss efficiency (η_0)	0.74	--
First-order coefficient (a_1)	4.58	W/(m²K)
Second-order coefficient (a_2)	0.007	W/(m²K²)
Incidence angle modifier IAM (50°)	0.95	--

Remark: The data given in this section are related to collector reference area (A_{sol}) which is aperture area for values according to EN 12975-2 or gross area for ISO 9806. Consistent data sets for either aperture or gross area can be used in calculations like in the regulation 811 and 812 and simulation programs.

DIN CERTCO ● Alboinstraße 56 ● 12103 Berlin, Germany
Tel: +49 30 7562-1131 ● Fax: +49 30 7562-1141 ● E-Mail: info@dincertco.de ● www.dincertco.de